



ENDOT INDUSTRIES, INC.

PIPE AND TUBING • DUCT AND INNERDUCT

CERTIFICATE OF COMPLIANCE

Endot Industries, Inc. certifies that the product(s) listed are produced and tested in accordance with the standards listed below and meet or exceed these standards.

ENDOPOLY

200 PSI - PE 3408/PE 4710

APPLICABLE STANDARDS:

NSF	Certified by NSF and Listed Under Standard 14 & 61 for Potable Water
ASTM D3350	Cell Classification 445574A - for raw material - (445574C for final product)
ASTM D2239	Conforms to PE 3408/ PE 4710, 200 PSI, SIDR 7 (IPS)
AWWA C901-96	Conforms as 200 PSI SIDR 7 (IPS)
BOCA	Conforms as 200 PSI SIDR 7 (IPS)
Product Requirements:	Color – Black with a minimum 2% carbon black content. Permanent Indent printing with Lot & Date Code every two feet. Lifetime Warranty with 25 year cost of replacement.
Product Application:	EndoPoly water service pipe and tubing is suitable for use in potable water systems and pressurized sewer main systems.

WATER SERVICE PIPE (IPS) - ASTM D2239

STANDARD INSIDE DIAMETER RATIO (SIDR) = 7

SIZE	NOMINAL O.D.	NOMINAL I.D.	MINIMUM WALL	WEIGHT PER 100 FT.	STANDARD COIL SIZE
3/4	1.070	.824	.118	15.5	400/100
1	1.359	1.049	.150	24.9	300/200/100
1-1/4	1.785	1.380	.197	42.8	300/100
1-1/2	2.086	1.610	.230	58.4	250/100
2	2.675	2.067	.295	96.2	200/100

For Endot Industries, Inc.

Richard G. Kraft, V.P. Sales and Marketing

ENDOT INDUSTRIES, INC.

www.endot.com - e-mail info@endot.com

CORPORATE HEADQUARTERS: 60 Green Pond Road, Rockaway, NJ 07866 – 800 443 6368 – FAX 973 625 4087

MID-WEST OPERATIONS: 739 County Road 1, South Point, OH 45680 – 800 345 3990 – FAX 740 377 9844

TENNESSEE OPERATIONS: 400 Bohannon Avenue, Greeneville, TN 37745 – 800 438 5851 – FAX 423 639 3722

OKLAHOMA OPERATIONS: Mid America Industrial Park, Pryor Creek, OK 74361 – 800 443 6368 – FAX 973 625 4087