

ENDOT INDUSTRIES

PIPE AND TUBING PRODUCTS

SUGGESTED LIST PRICES
MARCH 1, 1995

PE 3406 PREMIUM HIGH DENSITY POLYETHYLENE

“ULTRA GOLDEN JET”

“SUPER GOLDEN JET”
“BLACK-DIAMOND”

“GOLDEN JET”

POLYWRAPPED COILS

Meets the Requirements of ASTM D2239

<u>SIZE</u>	<u>O.D.</u>	<u>I.D.</u>	<u>Min. Wall</u>	<u>Weight Per 100'</u>	<u>Standard Coil Size</u>	<u>Price Per 100'</u>
“SUPER GOLDEN JET”			160 PSI —	@73.4°F (IPS) —	SIDR 7 —	DEEP WELL & WATER SERVICE PIPE
1"	1.359	1.049	.150	24.1	600/400/300/200/100	108.65
1¼"	1.785	1.380	.197	41.5	300/100	187.70
“GOLDEN JET”			— 100 PSI —	@73.4°F (IPS) —	SIDR 11.5 —	WATER PIPE
½"	.750	.622	.060	5.7	400/100	26.00
¾"	.976	.824	.072	9.0	400/100	40.55
1"	1.239	1.049	.091	14.2	1000/500/300/200/100	64.00
1¼"	1.630	1.380	.120	24.3	300/100	110.00
1½"	1.900	1.610	.140	32.9	250/100	155.00
2"	2.437	2.067	.180	54.1	200/100	257.00
“BLACK-DIAMOND”			— 80 PSI —	@73.4°F (IPS) —	SIDR 15 —	WATER PIPE
¾"	.952	.824	.060	7.5	400/100	34.00
1"	1.207	1.049	.070	10.9	300/100	49.20
1¼"	1.572	1.380	.092	18.5	300/100	84.25

STANDARDS: PE 3406 type pipe meets all the applicable standards of ASTM D1248 (D4976), ASTM D2239, NSF-14 & BOCA.

GUARANTEE: ENDOT pipe and tubing is guaranteed against rot, rust and electrolytic corrosion and to be free of defects in material and workmanship. ENDOT's liability will be limited to the replacement of pipe or tubing acknowledged to be defective. (See Warranty for details)
Use of pipe sealing compounds, pipe dope and detergent type lubricants voids all warranties.

NOTE: Use insert fittings for all sizes and pressure ratings. Compression fittings for 200 PSI & 160 PSI PIPE must be selected according to SIDR RATING NOT PRESSURE RATING.

ENDOT INDUSTRIES, INC.

www.endot.com • e-mail: info@endot.com



CORPORATE HEADQUARTERS • 60 Green Pond Road, Rockaway, NJ 07866 • 800-443-6368 • FAX 973-625-4087
MID-WEST OPERATIONS • 739 County Road 1, South Point, OH 45680 • 800-345-3990 • FAX 740-377-9844
TENNESSEE DIVISION • 400 Bohannon Avenue, Greeneville, TN 37745 • 800-438-5851 • FAX 423-639-3722